

TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932
409/565-2273

59839 Hwy 191, Anacoco, LA 71403
337/286-5244 (Office)
337/286-5253 (Message)

ADVISORY # 6

DATE: Thursday, May 15, 2025

EVENT OVER-OPERATIONS BACK TO NORMAL TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 1630 hrs

RESERVOIR ELEV: 171.99 FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 5000 cfs TO 300 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES – ALL GATES CLOSED

Number of Gates	Opened (Feet)
<u>1</u>	<u>0.3</u>

GENERATORS

Generator #	Current Status
<u>1</u>	<u>24 hrs @ 7456 cfs</u>
<u>2</u>	<u>24 hrs @ 6033 cfs</u>

TOTAL RELEASES

	(CFS)
SPILLWAY	<u>300</u>
GENERATORS	<u>13489</u>
TOTAL	<u>13789</u>

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and www.setexasrain.org. Information on specific river gages can be obtained from the National Weather Service at the following website: <http://www.weather.gov/wgrfc> and from the USGS at the following websites: <http://waterdata.usgs.gov/tx/nwis/rt> or <https://waterdata.usgs.gov/state/louisiana/>.

Actual flooding conditions may vary significantly from the alert based on new or changed conditions; advanced alerts of changed conditions may not be possible.